

## PERRP Most Common Violations by Standard CY 2015

| Rank | Standard                  | Condition  | # of Findings |
|------|---------------------------|--|---------------|
| 1    | 29 CFR 1910.305(g)(1)(iv) | Flexible cords and cables were improperly used.  | 131           |
| 2    | 29 CFR 1910.37(a)(4)      | Safeguards designed to protect employees during an emergency were not in proper working order.   | 101           |
| 3    | 29 CFR 1910.215(b)(9)     | Abrasive wheel grinder upper (tongue) guard was missing or improperly adjusted.  | 88            |
| 4    | 29 CFR 1910.22(a)(1)      | The workplace was not kept clean and orderly, or in a sanitary condition.  | 82            |
| 5    | 29 CFR 1910.303(b)(2)     | Listed or labeled electrical equipment was improperly used or installed.   | 81            |
| 6    | 29 CFR 1910.304(g)(6)(vi) | Exposed noncurrent-carrying metal parts of cord and plug connected equipment that may become energized were not grounded.  | 69            |
| 7    | 29 CFR 1910.303(b)(1)(iv) | Electrical equipment was not free from recognized hazards due to inadequate electrical insulation.   | 68            |
| 8    | 29 CFR 1910.157(e)(2)     | Portable fire extinguishers were not visually inspected at least monthly.  | 66            |
| 9    | 29 CFR 1910.303(g)(1)(ii) | Working space about electric equipment was used for storage.   | 66            |
| 10   | 29 CFR 1910.215(a)(4)     | Abrasive wheel grinder work rest(s) was missing or improperly adjusted.  | 64            |
| 11   | 29 CFR 1910.303(b)(7)(iv) | Electrical equipment had damaged parts that may adversely affect safe operation or mechanical strength (e.g., parts that were broken, bent, cut, or deteriorated by corrosion, chemical action, or overheating). | 61            |
| 12   | 29 CFR 1910.303(b)(1)(ii) | Unused openings in electrical equipment were not effectively closed.   | 60            |
| 13   | 29 CFR 1910.303(f)(2)     | Electrical circuits or disconnects were unlabeled.   | 57            |
| 14   | 29 CFR 1910.212(a)(1)     | Machine guarding was not provided to protect the operator and other employees in the machine area.   | 56            |
| 15   | 29 CFR 1910.212(a)(3)(ii) | The point of operation of a machine, whose operation exposes an employee to injury, was not guarded.   | 56            |
| 16   | 29 CFR 1910.151(c)        | Suitable eyewash and/or body drenching facilities were not provided in the work area.  | 54            |
| 17   | 29 CFR 1910.212(b)        | Machine(s) designed for fixed location(s) were not securely anchored to prevent walking or moving.   | 53            |
| 18   | 29 CFR 1910.303(g)(2)(ii) | Electrical equipment exposed to damage was not guarded.  | 45            |
| 19   | 29 CFR 1910.132(a)        | Personal protective equipment was not used when necessary and/or not maintained in a sanitary & reliable condition.  | 42            |
| 20   | 29 CFR 1910.335(b)(1)     | Safety signs, safety symbols, or accident prevention tags were not used where necessary to warn employees about electrical hazards which may endanger them.  | 40            |
| 21   | 29 CFR 1910.304(g)(5)     | The path to ground from circuits, equipment, and enclosures were not permanent, continuous, and effective.   | 39            |
| 22   | 29 CFR 1910.304(b)(4)     | Outlet devices did not have an ampere rating that was less than the load to be served.   | 38            |
| 23   | 29 CFR 1910.305(b)(1)(ii) | Unused openings in electrical equipment were not effectively closed.   | 38            |
| 24   | 29 CFR 1910.157(c)(1)     | Portable fire extinguishers were not readily accessible to employees without subjecting employees to possible injury.  | 37            |
| 25   | 29 CFR 1910.184(e)(1)     | Alloy steel sling(s) did not have permanently affixed durable identification stating size, grade, rated capacity, and reach.   | 36            |

ORC 4167.04(A)(1) — General Duty Clause was cited 37 times.

V1.0 05-19-2016

Source: Ohio Bureau of Workers' Compensation, Public Employment Risk Reduction Program