

PERRP Most Common Violations by Standard CY 2009

Rank	Standard	Condition	# of Findings*
1	29 CFR 1910.303(b)(2)	Listed or labeled electrical equipment was improperly used or installed.	521
2	29 CFR 1910.305(g)(1)(iv)	Flexible cords and cables were improperly used.	507
3	29 CFR 1910.304(g)(6)(vi)	Exposed noncurrent-carrying metal parts of cord and plug connected equipment that may become energized were not grounded.	331
4	29 CFR 1910.303(b)(1)(ii)	Strength or durability of electrical equipment was inadequate.	327
5	29 CFR 1910.303(b)(1)(iv)	Electrical equipment had inadequate insulation.	298
6	29 CFR 1910.1200(f)(5)	Container(s) of hazardous chemicals were not labeled.	289
7	29 CFR 1910.303(f)(2)	Electrical circuits or disconnects were unlabeled.	274
8	29 CFR 1910.22(a)(1)	The workplace was not kept clean and orderly, or in a sanitary condition.	267
9	29 CFR 1910.303(g)(2)(ii)	Electric equipment exposed to damage was not guarded.	259
10	29 CFR 1910.303(g)(1)(ii)	Working space about electric equipment was used for storage.	251
11	29 CFR 1910.37(a)(4)	Safeguards designed to protect employees during an emergency were not in proper working order.	242
12	29 CFR 1910.151(c)	Suitable eyewash and/or body drenching facilities were not provided in the work area.	240
13	29 CFR 1910.305(b)(1)(ii)	Unused openings in electrical equipment were not effectively closed.	238
14	29 CFR 1910.215(b)(9)	Abrasive wheel grinder upper (tongue) guard was missing or improperly adjusted.	204
15	29 CFR 1910.305(b)(2)(i)	Pull boxes, junction boxes, outlet boxes or fittings were not provided with covers approved for its purpose.	177
16	29 CFR 1910.212(b)	Machine(s) designed for fixed location(s) were not securely anchored to prevent walking or moving.	165
17	29 CFR 1910.157(e)(2)	Portable fire extinguishers were not visually inspected at least monthly.	158
18	29 CFR 1910.304(g)(5)	Equipment ground connection was not permanent and continuous.	158
19	29 CFR 1910.305(a)(2)(ix)	Temporary lamps for general illumination were not protected with a suitable fixture or lampholder with a guard.	149
20	29 CFR 1910.132(a)	PPE was not provided, used or maintained in a sanitary and reliable condition.	127
21	29 CFR 1910.243(b)(2)	Hose and hose connections used for conducting compressed air to utilization equipment were not designed for the pressure and service to which they are subject to.	119
22	OAC 4167.06	Recording and Reporting Injuries and Illnesses	113
23	29 CFR 1910.334(a)(3)(ii)	Attachment plugs and receptacles were connected or altered in a manner which prevented proper continuity of the equipment grounding conductor.	113
24	29 CFR 1910.303(b)(1)(i)	Electrical equipment was not listed or labeled for its identified purpose.	111
25	29 CFR 1910.212(a)(3)(ii)	The point of operation was not guarded on machine(s) whose operation exposed an employee to injury.	108
*NOTE: Number of Findings reflects total number of hazards identified during consultative and enforcement visits.			