

PERRP Most Common Violations by Standard CY 2012

Rank	Standard	Condition	# of Findings*
1	29 CFR 1910.305(g)(1)(iv)	Flexible cords and cables were improperly used.	259
2	29 CFR 1910.37(a)(4)	Safeguards designed to protect employees during an emergency were not in proper working order.	234
3	29 CFR 1910.305(b)(1)(ii)	Unused openings in electrical equipment were not effectively closed.	226
4	29 CFR 1910.303(b)(2)	Listed or labeled electrical equipment was improperly used or installed.	214
5	29 CFR 1910.304(g)(6)(vi)	Exposed noncurrent-carrying metal parts of cord and plug connected equipment that may become energized were not grounded.	202
6	29 CFR 1910.215(b)(9)	Abrasive wheel grinder upper (tongue) guard was missing or improperly adjusted.	201
7	29 CFR 1910.22(a)(1)	The workplace was not kept clean and orderly, or in a sanitary condition.	162
8	29 CFR 1910.215(a)(4)	Abrasive wheel grinder work rest(s) was missing or improperly adjusted.	154
9	29 CFR 1910.303(b)(1)(iv)	Electrical equipment was not free from recognized hazards due to inadequate electrical insulation.	150
10	29 CFR 1910.132(a)	Personal protective equipment was not used when necessary and/or not maintained in a sanitary & reliable condition.	135
11	29 CFR 1910.303(g)(1)(ii)	Working space about electric equipment was used for storage.	129
12	29 CFR 1910.305(b)(1)(ii)	Unused openings in electrical equipment were not effectively closed.	124
13	29 CFR 1910.303(b)(7)(iv)	Electrical equipment had damaged parts that may adversely affect safe operation or mechanical strength (e.g., parts that were broken, bent, cut, or deteriorated by corrosion, chemical action, or overheating).	123
14	29 CFR 1910.1200(f)(6)	Container(s) of hazardous chemicals were not labeled.	119
15	29 CFR 1910.303(f)(2)	Electrical circuits or disconnects were unlabeled.	119
16	29 CFR 1910.305(b)(2)(i)	Pull boxes, junction boxes, outlet boxes or fittings were not provided with covers approved for its purpose.	112
17	29 CFR 1910.151(c)	Suitable eyewash and/or body drenching facilities were not provided in the work area.	104
18	29 CFR 1910.157(e)(2)	Portable fire extinguishers were not visually inspected at least monthly.	104
19	29 CFR 1910.212(b)	Machine(s) designed for fixed location(s) were not securely anchored to prevent walking or moving.	100
20	29 CFR 1910.303(g)(2)(ii)	Electrical equipment exposed to damage was not guarded.	95
21	29 CFR 1910.212(a)(1)	Machine guarding was not provided to protect the operator and other employees in the machine area.	93
22	29 CFR 1910.212(a)(3)(ii)	The point of operation of a machine, whose operation exposes an employee to injury, was not guarded.	87
23	29 CFR 1910.157(c)(1)	Portable fire extinguishers were not readily accessible to employees without subjecting employees to possible injury.	86
24	29 CFR 1910.215(d)(1)	Wheel(s) on grinding machine(s) were not sounded (ring test) and inspected for damage before mounting.	73
25	29 CFR 1910.335(b)(1)	Safety signs, safety symbols, or accident prevention tags were not used where necessary to warn employees about electrical hazards which may endanger them.	71

ORC 4167.04(A)(1) — General Duty Clause was cited 55 times.

OAC 4167-6 — Injury and illnesses recordkeeping and reporting requirements were cited 78 times.