

4123:1-11-04 Drycleaning.

(A) Electrical equipment.

All electrical equipment shall be located outside the drycleaning room or be of an approved type for hazardous locations when any flammable liquid with a flash point below one hundred degrees Fahrenheit (37.8 degrees Celsius) is used for drycleaning.

(B) Stills and condensers.

Stills and condensers shall be of substantial construction, mounted on fire-resistive foundations and shall be of a type which will not expose the fluid or vapor to the atmosphere outside the still or condenser during any part of the process of reclamation.

(C) Brushing and prespotting.

- (1) Brushing and prespotting operations with flammable liquid solvents shall be performed in a drycleaning room, on a brushing table or in a tub.
- (2) Flammable liquid solvents used for brushing or prespotting shall be stored in approved portable safety containers.

(D) Drycleaning with nonflammable liquid solvents.

- (1) Where nonflammable solvents giving off air contaminants are used for drycleaning in quantities of more than one gallon, such operations shall be performed in fluid-tight machines, systems or apparatus.
- (2) Such apparatus shall be vented to the open air at a point no less than twenty-five feet from any window or other openings, and so used and operated to prevent the escape of air contaminants therefrom into the workrooms and work spaces.

Effective: 3/15/10
Prior Effective Dates: 4/1/64, 9/1/81