

## PERRP Most Common Violations by Standard CY 2018

Rank	Standard	Condition	# of Findings
1	29 CFR 1910.305(g)(1)(iv)	Flexible cords and cables were improperly used.	61
2	29 CFR 1910.1200(e)(1)	A written hazard communication program was not developed, implemented, and/or maintained at the workplace.	38
3	29 CFR 1910.305(b)(1)(ii)	Unused openings in cabinets, boxes, and fittings were not effectively closed.	38
4	29 CFR 1910.303(b)(2)	Listed or labeled electrical equipment was not used or installed in accordance with instructions included in the listing or labeling.	29
5	29 CFR 1910.37(a)(4)	Safeguards designed to protect employees during an emergency were not in proper working order.	29
6	29 CFR 1910.303(b)(1)(ii)	Equipment did not have adequate mechanical strength and durability, including, parts that were designed to enclose and protect other equipment.	27
7	29 CFR 1910.334(a)(3)(ii)	Attachment plugs and receptacles were connected or altered.	27
8	29 CFR 1910.215(b)(9)	Abrasive wheel grinder upper (tongue) guard was missing or improperly adjusted.	25
9	29 CFR 1910.157(e)(2)	Portable fire extinguishers were not visually inspected at least monthly.	24
10	29 CFR 1910.303(g)(1)(ii)	Working space about electric equipment was used for storage.	22
11	29 CFR 1910.212(a)(3)(ii)	Point(s) of operation of machinery were not guarded.	21
12	29 CFR 1910.334(a)(2)(ii)	Defective or damaged portable electric equipment was not removed from service.	21
13	29 CFR 1910.141(b)(2)(ii)	An anti-siphoning device was not installed in order to prevent backflow or back siphonage into the potable water system.	20
14	29 CFR 1910.305(b)(2)(i)	Each outlet box did not have a cover, faceplate, or fixture canopy.	19
15	29 CFR 1910.212(a)(1)	Machine guarding was not provided to protect the operator and other employees in the machine area from hazards.	18
16	29 CFR 1910.215(a)(4)	Abrasive wheel grinder work rest(s) was missing or improperly adjusted	16
17	29 CFR 1910.303(g)(2)(ii)	Electrical equipment likely to be exposed to physical damage, did not have enclosures or guards of adequate strength to prevent damage.	16
18	29 CFR 1910.101(b)	The storage and utilization of all compressed gases were not in accordance with Compressed Gas Association Pamphlet P-1.	15
19	29 CFR 1910.242(b)	Compressed air used for cleaning purposes was not reduced to less than 30 p.s.i.	15
20	29 CFR 1910.151(c)	Suitable eyewash and/or body drenching facilities were not provided in the work area.	14
21	29 CFR 1910.334(a)(2)(i)	A portable cord and plug connected piece of equipment was not visually inspected for evidence of external or internal defects or damage.	14
22	29 CFR 1910.212(b)	Machine(s) designed for fixed location(s) were not securely anchored to prevent walking or moving.	13
23	29 CFR 1910.242(a)	Hand and portable powered tools or equipment were not kept in safe condition.	13
24	29 CFR 1910.22(a)(1)	The place of employment, passageways, storerooms, service rooms, and walking-working surfaces were not kept clean, orderly, or in a sanitary condition.	11
25	29 CFR 1910.303(b)(1)(i)	Electrical equipment was not suitable for installation and use in conformity with the provisions of this subpart.	11